


Site walk around checklist - water



Date of walk around _____

Area inspected _____

Staff present _____

	Undertaken (✓, X, n/a)	Action required (✓, X, n/a)	Date actioned
General			
Are there any visible pools of water, leaks or drips?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Can you hear any running or dripping water?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Toilets			
Is water needlessly discharging into the pan between flushes?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is the water in the cistern at the manufacturer's specified level?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Are previously installed water efficiency devices still in place and working correctly?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Urinals			
Is water needlessly discharging into urinals between flushes?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Are automatic urinal controls working correctly?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Taps			
Are any taps dripping or leaking when they are turned off?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Check the running time of push taps. Does this exceed 10 seconds?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is the flow rate between 4 and 6 litres per minute?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Showers			
Are any dripping when they are turned off?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Check the running time of push controls. Does this exceed 30 seconds?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is the flow rate between 8 and 10 litres per minute?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Equipment and storage			
Are ballcocks working correctly in storage tanks?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is water-using equipment operating correctly with no leaks or drips?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Are trigger nozzles fitted and working correctly on hoses?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is water-using equipment being left on when not needed (e.g. during breaks or production changeover)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Staff engagement			
Is water efficiency signage visible, clean and up to date in the kitchen area?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is water efficiency signage visible, clean and up to date in the cleaner's storeroom?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
Is signage visible in toilets?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="text"/>
A wide range of staff engagement materials including posters, stickers and staff training courses is available for free from www.resourceefficientscotland.com/staff-engagement-toolkit			

